

Ozone Generators that are Sold as Air Cleaners

On this page:

- Introduction and Purpose
- What is ozone?
- How is ozone harmful?
 - Ozone Health Effects and Standards
- Is there such a thing as "good ozone," and "bad ozone"?
- Are ozone generators effective in controlling indoor air pollution?
- If I follow manufacturers' directions, can I be harmed?
- Why is it difficult to control ozone exposure with an ozone generator?
- Can ozone be used in unoccupied spaces?
- What other methods can be used to control indoor air pollution?
- Conclusions
- Recommendation
- Additional Resources
- Publications
- Information Sources
- Bibliography

There is a large body of written material on ozone and the use of ozone indoors. However, much of this material makes claims or draws conclusions without substantiation and sound science. In developing ***Ozone Generators that are Sold as Air Cleaners***, the EPA reviewed a wide assortment of this literature, including information provided by a leading manufacturer of ozone generating devices. In keeping with EPA's policy of insuring that the information it provides is based on sound science, only peer reviewed, scientifically supported findings and conclusions were relied upon in developing this document.

Several brands of ozone generators have EPA establishment number on their packaging. This number helps EPA identify the specific facility that produces the product. **The display of this number does not imply EPA endorsement or suggest in any way that EPA has found the product to be either safe or effective.**

Please Note: EPA does not certify air cleaning devices. The Agency does not recommend air cleaning devices or manufacturers. If you need information on specific devices or manufacturers, one resource you can consult is the Association of Home Appliance Manufacturers (AHAM) [🔗 <https://www.aham.org>](https://www.aham.org), (202) 872-5955. AHAM conducts four certification programs for each category - room air cleaners, room air conditioners, dehumidifiers and refrigerator/freezers. The air cleaner certification program is known as AC-1.

Additional IAQ Resources

- Care for Your Air: A Guide to Indoor Air Quality
<<https://epa.gov/indoor-air-quality-iaq/care-your-air-guide-indoor-air-quality>>
- The Inside Story: A Guide to Indoor Air Quality
<<https://epa.gov/indoor-air-quality-iaq/inside-story-guide-indoor-air-quality>>
- Indoor Air Pollution: An Introduction for Health Professionals
<<https://epa.gov/indoor-air-quality-iaq/indoor-air-pollution-introduction-health-professionals>>
- Residential Air Cleaners (Third Edition) A Summary of Available Information
<<https://epa.gov/indoor-air-quality-iaq/air-cleaners-and-air-filters-home>>

Introduction and Purpose

Ozone generators that are sold as air cleaners intentionally produce the gas ozone. Often the vendors of ozone generators make statements and distribute material that lead the public to believe that these devices are always safe and effective in controlling indoor air pollution. For almost a century, health professionals have refuted these claims (Sawyer, et. al 1913; Salls, 1927; Boeniger, 1995; American Lung Association, 1997; Al-Ahmady, 1997). The purpose of this document is to provide accurate information regarding the use of ozone-generating devices in indoor occupied spaces. This information is based on the most credible scientific evidence currently available.

Some vendors suggest that these devices have been approved by the federal government for use in occupied spaces. To the contrary, **NO** agency of the federal government has approved these devices for use in occupied spaces. Because of these claims, and because ozone can cause health problems at high concentrations, several federal government agencies have worked in consultation with the U.S. Environmental Protection Agency to produce this public information document.

What is Ozone?

Ozone is a molecule composed of three atoms of oxygen. Two atoms of oxygen form the basic oxygen molecule – the oxygen we breathe that is essential to life. The third oxygen atom can detach from the ozone molecule, and re-attach to molecules of other substances, thereby altering their chemical composition. It is this ability to react with other substances that forms the basis of manufacturers' claims.

How is Ozone Harmful?

The same chemical properties that allow high concentrations of ozone to react with organic material outside the body give it the ability to react with similar organic material that makes up the body, and potentially cause harmful health consequences. When inhaled, ozone can damage the lungs. Relatively low amounts can cause chest pain, coughing, shortness of breath and throat irritation. Ozone may also worsen chronic respiratory diseases such as asthma and compromise the ability of the body to fight respiratory infections. People vary widely in their susceptibility to ozone. Healthy people, as well as those with respiratory difficulty, can experience breathing problems when exposed to ozone. Exercise during exposure to ozone causes a greater amount of ozone to be inhaled, and increases the risk of harmful respiratory effects. Recovery from the harmful effects can occur following short-term exposure to low levels of ozone, but health effects may become more damaging and recovery less certain at higher levels or from longer exposures (US EPA, 1996a, 1996b).

- [Ozone and Your Health \(pdf\)](https://www.airnow.gov/sites/default/files/2020-02/ozone-c.pdf) <<https://www.airnow.gov/sites/default/files/2020-02/ozone-c.pdf>> (2 pp, 2.5 MB)

Manufacturers and vendors of ozone devices often use misleading terms to describe ozone. Terms such as "energized oxygen" or "pure air" suggest that ozone is a healthy kind of oxygen. Ozone is a toxic gas with vastly different chemical and toxicological properties from oxygen. Several federal agencies have established health standards or recommendations to limit human exposure to ozone. These exposure limits are summarized in Table 1.

Table 1. Ozone Heath Effects and Standards

Health Effects	Risk Factors	Health Standards*
<p>Potential risk of experiencing:</p> <p>Decreases in lung function</p> <p>Aggravation of asthma</p> <p>Throat irritation and cough</p> <p>Chest pain and shortness of breath</p> <p>Inflammation of lung tissue</p> <p>Higher susceptibility to respiratory infection</p>	<p>Factors expected to increase risk and severity of health effects are:</p> <p>Increase in ozone air concentration</p> <p>Greater duration of exposure for some health effects</p> <p>Activities that raise the breathing rate (e.g., exercise)</p> <p>Certain pre-existing lung diseases (e.g., asthma)</p>	<p>The Food and Drug Administration (FDA) requires ozone output of indoor medical devices to be no more than 0.05 ppm.</p> <p>The Occupational Safety and Health Administration (OSHA) requires that workers not be exposed to an average concentration of more than 0.10 ppm for 8 hours.</p> <p>The National Institute of Occupational Safety and Health (NIOSH) recommends an upper limit of 0.10 ppm, not to be exceeded at any time.</p> <p>EPA's National Ambient Air Quality Standard for ozone is a maximum 8 hour average outdoor concentration of 0.08 ppm</p> <ul style="list-style-type: none"> • See - the Clean Air Act <https://epa.gov/clean-air-act-overview>
(* ppm = parts per million)		

Is There Such a Thing as "Good Ozone" and "Bad Ozone"?

The phrase "good up high - bad nearby" has been used by the U.S. Environmental Protection Agency (EPA) to make the distinction between ozone in the upper and lower atmosphere. Ozone in the upper atmosphere – referred to as "stratospheric ozone" – helps filter out damaging ultraviolet radiation from the sun. Though ozone in the stratosphere is protective, ozone in the atmosphere - which is the air we breathe - can be harmful to the respiratory system. Harmful levels of ozone can be produced by the interaction of sunlight with certain chemicals emitted to the environment (e.g., automobile emissions and chemical emissions of industrial plants). These harmful concentrations of ozone in the atmosphere are often accompanied by high concentrations of other pollutants, including nitrogen dioxide, fine particles and hydrocarbons. ***Whether pure or mixed with other chemicals, ozone can be harmful to health.***

- "Good up High - Bad Nearby" <<https://www.airnow.gov/publications/air-quality-animations/ozone-good-up-high-bad-nearby/>>
 - You can order the Office of Air Quality Planning and Standard's "**Good Up High Bad Nearby**", EPA publication number **EPA-451/K-03-001**, June 2003
- and
- Ozone and Your Health (pdf) <<https://www.airnow.gov/sites/default/files/2020-02/ozone-c.pdf>> (2 pp, 2.5 MB) EPA publication number **EPA-452/F-99-003**, September 1999

Are Ozone Generators Effective in Controlling Indoor Air Pollution?

Available scientific evidence shows that at concentrations that do not exceed public health standards, ozone has little potential to remove indoor air contaminants.

Some manufacturers or vendors suggest that ozone will render almost every chemical contaminant harmless by producing a chemical reaction whose only by-products are carbon dioxide, oxygen and water. This is misleading.

- First, a review of scientific research shows that, for many of the chemicals commonly found in indoor environments, the reaction process with ozone may take months or years (Boeniger, 1995). For all practical purposes, ozone does not react at all with such chemicals. And contrary to specific claims by some vendors, ozone generators are not effective in removing carbon monoxide (Salls, 1927; Shaughnessy et al., 1994) or formaldehyde (Esswein and Boeniger, 1994).
- Second, for many of the chemicals with which ozone does readily react, the reaction can form a variety of harmful or irritating by-products (Weschler et al., 1992a, 1992b, 1996; Zhang and Liou, 1994). For example, in a laboratory experiment that mixed ozone with chemicals from new carpet, ozone reduced many of these chemicals, including those which can produce new carpet odor. However, in the process, the reaction produced a variety of aldehydes, and the total concentration of organic chemicals in the air increased rather than decreased after the introduction of ozone (Weschler, et. al., 1992b). In addition to aldehydes, ozone may also increase indoor concentrations of formic acid (Zhang and Liou, 1994), both of which can irritate the lungs if produced in sufficient amounts. Some of the potential by-products produced by ozone's reactions with other chemicals are themselves very reactive and capable of producing irritating and corrosive by-products (Weschler and Shields, 1996, 1997a, 1997b). Given the complexity of the chemical reactions that occur, additional research is needed to more completely understand the complex interactions of indoor chemicals in the presence of ozone.
- Third, ozone does not remove particles (e.g., dust and pollen) from the air, including the particles that cause most allergies. However, some ozone generators are manufactured with an "ion generator" or "ionizer" in the same unit. An ionizer is a device that disperses negatively (and/or positively) charged ions into the air. These ions attach to particles in the air giving them a negative (or positive) charge so that the particles may attach to nearby surfaces such as walls or furniture, or attach to one another and settle out of the air. In recent experiments, ionizers were found to be less effective in removing particles of dust, tobacco smoke, pollen or fungal spores than either high efficiency particle filters or electrostatic precipitators. (Shaughnessy et al., 1994; Pierce, et al., 1996). However, it is apparent from other experiments that the effectiveness of particle air cleaners, including electrostatic precipitators, ion generators, or pleated filters varies widely (U.S. EPA, 1995).

There is evidence to show that at concentrations that do not exceed public health standards, ozone is not effective at removing many odor-causing chemicals.

- In an experiment designed to produce formaldehyde concentrations representative of an embalming studio, where formaldehyde is the main odor producer, ozone showed no effect in reducing formaldehyde concentration (Esswein and Boeniger, 1994). Other experiments suggest that body odor may be masked by the smell of ozone but is not removed by ozone (Wetheridge and Yaglou, 1939). Ozone is not considered useful for odor removal in building ventilation systems (ASHRAE, 1989).
- While there are few scientific studies to support the claim that ozone effectively removes odors, it is plausible that some odorous chemicals will react with ozone. For example, in some experiments, ozone appeared to react readily with certain chemicals, including some chemicals that contribute to the smell of new carpet (Weschler, 1992b; Zhang and Liou, 1994). Ozone is also believed to react with acrolein, one of the many odorous and irritating chemicals found in secondhand tobacco smoke (US EPA, 1995).

If used at concentrations that do not exceed public health standards, ozone applied to indoor air does not effectively remove viruses, bacteria, mold, or other biological pollutants.

- Some data suggest that low levels of ozone may reduce airborne concentrations and inhibit the growth of some biological organisms while ozone is present, but ozone concentrations would have to be 5 - 10 times higher than public health standards allow before the ozone could decontaminate the air sufficiently to prevent survival and regeneration of the organisms once the ozone is removed (Dyas, et al., 1983; Foarde et al., 1997).
 - Even at high concentrations, ozone may have no effect on biological contaminants embedded in porous material such as duct lining or ceiling tiles (Foarde et al, 1997). In other words, ozone produced by ozone generators may inhibit the growth of some biological agents while it is present, but it is unlikely to fully decontaminate the air unless concentrations are high enough to be a health concern if people are present. Even with high levels of ozone, contaminants embedded in porous material may not be affected at all.
-

If I Follow Manufacturers' Directions, Can I be Harmed?

Results of some controlled studies show that concentrations of ozone considerably higher than these standards are possible even when a user follows the manufacturer's operating instructions.

There are many brands and models of ozone generators on the market. They vary in the amount of ozone they can produce. In many circumstances, the use of an ozone generator may not result in ozone concentrations that exceed public health standards. But many factors affect the indoor concentration of ozone so that under some conditions ozone concentrations may exceed public health standards.

- In one study (Shaughnessy and Oatman, 1991), a large ozone generator recommended by the manufacturer for spaces "up to 3,000 square feet," was placed in a 350 square foot room and run at a high setting. The ozone in the room quickly reached concentrations that were exceptionally high – 0.50 to 0.80 ppm which is 5-10 times higher than public health limits (see Table 1.)
- In an EPA study, several different devices were placed in a home environment, in various rooms, with doors alternately opened and closed, and with the central ventilation system fan alternately turned on and off. The results showed that some ozone generators, when run at a high setting with interior doors closed, would frequently produce concentrations of 0.20 - 0.30 ppm. A powerful unit set on high with the interior doors opened achieved values of 0.12 to 0.20 ppm in adjacent rooms. When units were not run on high, and interior doors were open, concentrations generally did not exceed public health standards (US EPA, 1995).
- The concentrations reported above were adjusted to exclude that portion of the ozone concentration brought in from the outdoors. Indoor concentrations of ozone brought in from outside are typically 0.01- 0.02 ppm, but could be as high as 0.03 - 0.05 ppm (Hayes, 1991; U.S. EPA, 1996b; Weschler et al., 1989, 1996; Zhang and Liou; 1994). *If the outdoor portion of ozone were included in the indoor concentrations reported above, the concentrations inside would have been correspondingly higher, increasing the risk of excessive ozone exposure.*
- None of the studies reported above involved the simultaneous use of more than one device. The simultaneous use of multiple devices increases the total ozone output and therefore greatly increases the risk of excessive ozone exposure.

Why is it Difficult to Control Ozone Exposure with an Ozone Generator?

The actual concentration of ozone produced by an ozone generator depends on many factors. Concentrations will be higher if a more powerful device or more than one device is used, if a device is placed in a small space rather than a large space, if interior doors are closed rather than open and, if the room has fewer rather than more materials and furnishings that adsorb or react with ozone and, provided that outdoor concentrations of ozone are low, if there is less rather than more outdoor air ventilation.

The proximity of a person to the ozone generating device can also affect one's exposure. The concentration is highest at the point where the ozone exits from the device, and generally decreases as one moves further away.

Manufacturers and vendors advise users to size the device properly to the space or spaces in which it is used. Unfortunately, some manufacturers' recommendations about appropriate sizes for particular spaces have not been sufficiently precise to guarantee that ozone concentrations will not exceed public health limits. Further, some literature distributed by vendors suggests that users err on the side of operating a more powerful machine than would normally be appropriate for the intended space, the rationale being that the user may move in the future, or may want to use the machine in a larger space later on. Using a more powerful machine increases the risk of excessive ozone exposure.

Ozone generators typically provide a control setting by which the ozone output can be adjusted. The ozone output of these devices is usually **not** proportional to the control setting. That is, a setting at medium does not necessarily generate an ozone level that is halfway between the levels at low and high. The relationship between the control setting and the output varies considerably among devices, although most appear to elevate the ozone output much more than one

would expect as the control setting is increased from low to high. In experiments to date, the high setting in some devices generated 10 times the level obtained at the medium setting (US EPA, 1995). Manufacturer's instructions on some devices link the control setting to room size and thus indicate what setting is appropriate for different room sizes. However, room size is only one factor affecting ozone levels in the room.

In addition to adjusting the control setting to the size of the room, users have sometimes been advised to lower the ozone setting if they can smell the ozone. Unfortunately, the ability to detect ozone by smell varies considerably from person to person, and one's ability to smell ozone rapidly deteriorates in the presence of ozone. While the smell of ozone may indicate that the concentration is too high, lack of odor does not guarantee that levels are safe.

At least one manufacturer is offering units with an ozone sensor that turns the ozone generator on and off with the intent of maintaining ozone concentrations in the space below health standards. EPA is currently evaluating the effectiveness and reliability of these sensors, and plans to conduct further research to improve society's understanding of ozone chemistry indoors. EPA will report its findings as the results of this research become available.

Can Ozone be Used in Unoccupied Spaces?

Ozone has been extensively used for water purification, but ozone chemistry in water is not the same as ozone chemistry in air. High concentrations of ozone in air, **when people are not present**, are sometimes used to help decontaminate an unoccupied space from certain chemical or biological contaminants or odors (e.g., fire restoration). However, little is known about the chemical by-products left behind by these processes (Dunston and Spivak, 1997). While high concentrations of ozone in air may sometimes be appropriate in these circumstances, **conditions should be sufficiently controlled to insure that no person or pet becomes exposed**. Ozone can adversely affect indoor plants, and damage materials such as rubber, electrical wire coatings and fabrics and art work containing susceptible dyes and pigments (U.S. EPA, 1996a).

What Other Methods Can Be Used to Control Indoor Air Pollution?

The three most common approaches to reducing indoor air pollution <<https://epa.gov/indoor-air-quality-iaq/inside-story-guide-indoor-air-quality#three-basic>>, in order of effectiveness, are:

1. **Source Control:** Eliminate or control the sources of pollution;
2. **Ventilation:** Dilute and exhaust pollutants through outdoor air ventilation and
3. **Air Cleaning:** Remove pollutants through proven air cleaning methods.

Of the three, the first approach — **source control** — is the most effective. This involves minimizing the use of products and materials that cause indoor pollution, employing good hygiene practices to minimize biological contaminants (including the control of humidity and moisture, and occasional cleaning and disinfection of wet or moist surfaces), and using good housekeeping practices to control particles.

The second approach — **outdoor air ventilation** — is also effective and commonly employed. Ventilation methods include installing an exhaust fan close to the source of contaminants, increasing outdoor air flows in mechanical ventilation systems, and opening windows, especially when pollutant sources are in use.

The third approach — **air cleaning** — is not generally regarded as sufficient in itself, but is sometimes used to supplement source control and ventilation. Air filters, electronic particle air cleaners and ionizers are often used to remove airborne particles, and gas adsorbing material is sometimes used to remove gaseous contaminants when source control and ventilation are inadequate.

See Additional Resources section below for more detailed information about these methods.

Conclusions

Whether in its pure form or mixed with other chemicals, ozone can be harmful to health.

When inhaled, ozone can damage the lungs. Relatively low amounts of ozone can cause chest pain, coughing, shortness of breath and, throat irritation. It may also worsen chronic respiratory diseases such as asthma as well as compromise the ability of the body to fight respiratory infections.

Some studies show that ozone concentrations produced by ozone generators can exceed health standards even when one follows manufacturer's instructions.

Many factors affect ozone concentrations including the amount of ozone produced by the machine(s), the size of the indoor space, the amount of material in the room with which ozone reacts, the outdoor ozone concentration, and the amount of ventilation. These factors make it difficult to control the ozone concentration in all circumstances.

Available scientific evidence shows that, at concentrations that do not exceed public health standards, ozone is generally ineffective in controlling indoor air pollution.

The concentration of ozone would have to greatly exceed health standards to be effective in removing most indoor air contaminants. In the process of reacting with chemicals indoors, ozone can produce other chemicals that themselves can be irritating and corrosive.

Recommendation

The public is advised to use proven methods of controlling indoor air pollution. These methods include eliminating or controlling pollutant sources, increasing outdoor air ventilation and using proven methods of air cleaning.

Additional Resources

See Indoor Air Quality Publications <<https://epa.gov/indoor-air-quality-iaq/publications-about-indoor-air-quality>>

Publications

- The Inside Story: A Guide to Indoor Air <<https://epa.gov/indoor-air-quality-iaq/inside-story-guide-indoor-air-quality>>, EPA Document Number EPA 402-K-93-007. U.S. EPA, U.S. CPSC. April 1995.
 - Guide to Air Cleaners in the Home (Second Edition) <<https://epa.gov/indoor-air-quality-iaq/air-cleaners-and-air-filters-home>> This brochure replaces "Residential Air Cleaners - Indoor Air Facts No. 7, EPA 20A-4001, February 1990.", EPA 402-F-08-004, May 2008
 - Residential Air Cleaners (Third Edition) A Summary of Available Information <<https://epa.gov/indoor-air-quality-iaq/air-cleaners-and-air-filters-home>>
 - Indoor Air Pollution: An Introduction for Health Professionals, <<https://epa.gov/indoor-air-quality-iaq/indoor-air-pollution-introduction-health-professionals-printable-version>> EPA Document Number EPA 402-R-94-007. American Lung Association, EPA, CPSC, American Medical Association.
-

Information Sources

California Department of Health Services, Indoor Air Quality Program, DHS-IAQ Program Assistance Line: (510) 620-2874, Fax: (510) 620-2825

Federal Trade Commission [🔗](https://www.ftc.gov/) <<https://www.ftc.gov/>>, Consumer Response Center, (202) 326-3128.

U.S. Consumer Product Safety Commission [🔗](https://www.cpsc.gov/) <<https://www.cpsc.gov/>>, or call Consumer Hotline, English/Spanish: (800) 638-2772, Hearing/Speech Impaired: (800) 6388270.

The Association of Home Appliance Manufacturers (AHAM) has developed an American National Standards Institute (ANSI)-approved standard for portable air cleaners (ANSI/AHAM Standard AC-1-1988). This standard may be useful in estimating the effectiveness of portable air cleaners. Under this standard, room air cleaner effectiveness is rated by a clean air delivery rate (CADR) for each of three particle types in indoor air: tobacco smoke, dust and pollen. Only a limited number of air cleaners had been certified under this program when this document was written.

A listing of AHAM-certified room air cleaners and their CADRs can be obtained from AHAM Verified [✉](https://ahamverifide.org/directory-of-air-cleaners/)

<<https://ahamverifide.org/directory-of-air-cleaners/>>.

Association of Home Appliance Manufacturers (AHAM) [✉](https://www.aham.org) <<https://www.aham.org>>

(202) 872-5955

Bibliography

1. Al-Ahmady, Kaiss K. 1997. Indoor Ozone. *Florida Journal of Environmental Health*. June. pp. 8-12.
2. American Lung Association. 1997. Residential Air Cleaning Devices: Types, Effectiveness and Health Impact. Washington, D.C. January.
3. American Society of Heating, Refrigerating and Air Conditioning Engineers (ASHRAE). 1989. *ASHRAE Handbook of Fundamentals*. Atlanta. p. 12.5.
4. Boeniger, Mark F. 1995. Use of Ozone Generating Devices to Improve Indoor Air Quality. *American Industrial Hygiene Association Journal*. 56: 590-598.
5. Dunston, N.C.; Spivak, S.M. 1997. A Preliminary Investigation of the Effects of Ozone on Post-Fire Volatile Organic Compounds. *Journal of Applied Fire Science*. 6(3): 231-242.
6. Dyas, A.; Boughton, B.J.; Das, B.C. 1983. Ozone Killing Action Against Bacterial and Fungal Species; Microbiological Testing of a Domestic Ozone Generator. *Journal of Clinical Pathology*. 36:1102-1104.
7. Esswein, Eric J.; Boeniger, Mark F. 1994. Effects of an Ozone-Generating Air-Purifying Device on Reducing Concentrations of Formaldehyde in Air. *Applied Occupational Environmental Hygiene*. 9(2):139-146.
8. Foarde, K.; van Osdell, D.; and Steiber, R.1997. Investigation of Gas-Phase Ozone as a Potential Biocide. *Applied Occupational Environmental Hygiene*. 12(8): 535-542.
9. Hayes, S.R. 1991. Use of an Indoor Air Quality Model (IAQM) to Estimate Indoor Ozone Levels. *Journal of Air and Waste Management Association*. 41:161-170.
10. Pierce, Mark W.; Janczewski, Jolanda N.; Roethlisberger, Brian; Pelton, Mike; and Kunstel, Kristen. 1996. Effectiveness of Auxiliary Air Cleaners in Reducing ETS Components in Offices. *ASHRAE Journal*. November.
11. Salls, Carroll, M. 1927. The Ozone Fallacy in Garage Ventilation. *The Journal of Industrial Hygiene*. 9:12. December.
12. Sawyer, W.A.; Beckwith, Helen I.; and Skolfield, Esther M. 1913. The Alleged Purification of Air By The Ozone Machine. *Journal of the American Medical Association*. November 13.
13. Shaughnessy, Richard, J.; Levetin, Estelle; Blocker, Jean; and Sublette, Kerry L. 1994. Effectiveness of Portable Indoor Air Cleaners: Sensory Testing Results. *Indoor Air*. Journal of the International Society of Indoor Air Quality and Climate. 4:179-188.
14. Shaughnessy, R.J.; and Oatman, L. 1991. The Use of Ozone Generators for the Control of Indoor Air Contaminants in an Occupied Environment. *Proceedings of the ASHRAE Conference IAQ '91. Healthy Buildings*. ASHRAE, Atlanta.
15. U.S. Environmental Protection Agency (US EPA). 1995. Ozone Generators in Indoor Air Settings. Report prepared for the Office of Research and Development by Raymond Steiber. National Risk Management Research Laboratory. U.S. EPA. Research Triangle Park. EPA-600/R-95-154.
16. U.S. Environmental Protection Agency (US EPA). 1996. Air Quality Criteria for Ozone and Related Photochemical Oxidants. Research Triangle Park, NC: National Center for Environmental Assessment-RTP Office; report nos. EPA/600/P-93/004aF-cF, 3v. NTIS, Springfield, VA; PB-185582, PB96-185590 and PB96-185608.
17. U.S. Environmental Protection Agency (US EPA). 1996. Review of National Ambient Air Quality Standards for Ozone: Assessment of Scientific and Technical Information. OAQPS Staff Paper. Office of Air Quality Planning and Standards. Research Triangle Park. NC. EPA-452/R-96-007.

18. Weschler, Charles J.; Brauer, Michael; and Koutrakis, Petros. 1992a. Indoor Ozone and Nitrogen Dioxide: A Potential Pathway to the Generation of Nitrate Radicals, Dinitrogen Pentaoxide and Nitric Acid Indoors. *Environmental Science and Technology*. 26(1):179-184.
 19. Weschler, Charles J.; Hodgson Alfred T.; and Wooley, John D. 1992b. Indoor Chemistry: Ozone, Volatile Organic Compounds and Carpets. *Environmental Science and Technology*. 26(12):2371-2377.
 20. Weschler, Charles J.; Shields, Helen C. 1997a. Measurements of the Hydroxyl Radical in a Manipulated but Realistic Indoor Environment. *Environmental Science and Technology*. 31(12):3719-3722.
 21. Weschler, Charles J.; Shields, Helen C. 1997b. Potential Reactions Among Indoor Pollutants. *Atmospheric Environment*. 31(21):3487-3495.
 22. Weschler, Charles J.; and Shields, Helen C. 1996. Production of the Hydroxyl Radical in Indoor Air. *Environmental Science and Technology*. 30(11):3250-3268.
 23. Weschler, Charles J.; Shields, Helen, C.; and Naik, Datta V. 1989. Indoor Ozone Exposures. *JAPCA Journal*. 39(12):1562-1568.
 24. Weschler, Charles J.; Shields, Helen, C.; and Naik, Datta V. 1996. The Factors Influencing Indoor Ozone Levels at a Commercial Building in Southern California: More than a Year of Continuous Observations. *Tropospheric Ozone*. Air and Waste Management Association. Pittsburgh.
 25. Witheridge, William N. And Yaglou, Constantin P. 1939. Ozone in Ventilation – Its possibilities and Limitations. *ASHRAE Transactions*. 45: 509-522.
 26. Zhang, Junfeng and Liou, Paul J. 1994. Ozone in Residential Air: Concentrations, I/O Ratios, Indoor Chemistry and Exposures. *Indoor Air*. Journal of the International Society of Indoor Air Quality and Climate. 4:95-102.
-